Cooling Towers:

 $COP = \frac{BTUH}{Watts \times 3.41}$

Tower approach: *LWT – EATwb*

Coefficient of performance:

© 2005, National Energy Management Institute Committee. All rights reserved.